

MATERIALS DEPARTMENT
BUILDING MATERIALS LABORATORY (LM)

TEST REPORT N° LM00-06052/15/R25NM (English version)

Client: **Selena Labs Sp. z o.o.**
Client address: **55-011 Siechnice, Polna, POLAND**

Information about test item

Test item: *thermo-reflexive roofing coating COOL-R*
Date of receipt /sampling: *25.08.2015*
N° of receipt /sampling protocol: *LM00-06025/15/R25NM*
Receipt /sampling procedure: *management procedure no 18*

Information about tests:

Test commencement date: *18.09.2015*
Test completion date: *12.10.2015*

Results of tests:

Laboratory tests have been taken acc to PN-EN 13416:2004. Not found any visible defects of the samples, acc to PN-EN 1850-2:2004.

Nº	Properties	The result of test	Test methods
1	Watertightness under the pressure of 0,2MPa in 24 hours The result of tests	Watertight; Watertight; Watertight <hr/> Positive under the pressure of 0,2MPa	PN-EN 1928:2002 method B; The samples have been prepared acc to producent's technical data on the substrate – cardboard, variety of „400”

Further information about tests: -

Responsible for the test:

Ph. D. eng. Barbara Francke

Authorizing person

MSc. eng. Jolanta Wiktorek

Warsaw, 26.10.2015

Testing Laboratory declares that test results relate only to the object under test. Test Report should not be reproduced without a written permission of Testing Laboratory in any other form than as a whole.

Test Report is not substitute for documents required for placing on the market and making available of construction products

The head of laboratory LM:

MSc. eng. Jadwiga Miklaszewska

LABORATORIUM MATERIAŁÓW BUDOWLANYCH

Warszawa | ul. Filtrowa 1 | tel. 225796492, 225796181 | fax 225796291

Instytut Techniki Budowlanej
00-611 Warszawa | ul. Filtrowa 1 | tel. 22 825 04 71 | fax 22 825 52 86 | Dyrektor tel. 22 825 28 85 | 22 825 13 03 | fax 22 825 77 30 | 02-656 Warszawa | ul. Ksawerów 21 | tel. 22 843 14 71 | fax 22 843 29 31 | KRS: 0000158785 | Regon: 000063650 | NIP: 525 000 93 58 | PKO S.A. O/Warszawa | ul. Nowogrodzka 11 | 00-513 Warszawa | nr konta 7712405918111000049134568 | www.itb.pl | instytut@itb.pl